

KANAWHA FALLS PSD

WV3301037

Consumer Confidence Report – 2026

Covering Calendar Year – 2025

This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affects drinking water quality or if you have any questions, comments or suggestions, please attend any regularly scheduled water board meeting held on the **[2nd Thursday]** of each month at 400pm at 362 Gauley River Rd Gauley Bridge WV or call Bob Scott at 304-632-1633

Your water comes from Surface water:

Source Name	Source Water Type
KANAWHA RIVER - INTAKE	Surface water

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in sources water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the number of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system has an estimated population of 2547 and is required to test a minimum of 3 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2025 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2025. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): the "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Secondary Maximum Contaminant Level (SMCL): recommended level for a contaminant that is not regulated and has no MCL.

Action Level (AL): the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

Treatment Technique (TT): a required process intended to reduce levels of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-Detects (ND): lab analysis indicates that the contaminant is not present.

Parts per Million (ppm): or milligrams per liter (mg/L)

Parts per Billion (ppb): or micrograms per liter (µg/L)

Picocuries per Liter (pCi/L): a measure of the radioactivity in water.

Millirems per Year (mrem/yr): measure of radiation absorbed by the body.

Monitoring Period Average (MPA): An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

Nephelometric Turbidity Unit (NTU): a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

Running Annual Average (RAA): an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

Locational Running Annual Average (LRAA): Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Testing Results for: KANAWHA FALLS PSD

Regulated Contaminants	Facility Name	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
BARIUM	TREATMENT PLANT	11/14/2024	0.0264	0.0264	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE	TREATMENT PLANT	1/28/2025	0.75	0.75	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE	TREATMENT PLANT	5/28/2025	0.46	0.44 - 0.46	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Collection Date	Highest LRAA Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	362 GAULEY RIVER ROAD, PSD OFFICE	2025	37	19 - 19	ppb	60	0	By-product of drinking water disinfection
TTHM	362 GAULEY RIVER ROAD, PSD OFFICE	2025	34	14 - 14	ppb	80	0	By-product of drinking water chlorination

Lead and	Monitoring	90TH	Range	Unit	AL	Sites Over	Typical Source
----------	------------	------	-------	------	----	------------	----------------

Copper	Period	Percentile	(low/high)			AL	
COPPER, FREE	2023 - 2025	0.119	0.0013 - 0.2	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2023 - 2025	0.93	0 - 3.9	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. KANAWHA FALLS PSD is responsible for providing high-quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact KANAWHA FALLS PSD and Bob Scott at 304-632-1633. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

KANAWHA FALLS PSD completed lead tap sampling in 2023 - 2025 the results are available for review and can be accessed <https://ccrwater.net/kanawhafallspsd-256803> ..

KANAWHA FALLS PSD has prepared a service line inventory identifying service line materials throughout the water distribution supply. The most up to date inventory is located at **[Location or Website URL]**. By November 1, 2027, our water system must develop an updated initial inventory, known as the "baseline inventory" and it must include each service line and identified connector that is connected to the public water distribution system.

Our water system identified **[lead, galvanized requiring replacement, or lead status unknown]** service lines in our inventory. Due to this identification our water system must create a service line replacement plan by November 1, 2027.

If you have any questions about our inventory or if you would like information about our service line replacement plan, please contact Joseph Goodnite at 304-632-1633.

Source Water Assessment and Protection

When required by West Virginia State law, KANAWHA FALLS PSD maintains a comprehensive **Source Water Protection Plan (SWPP)** that is updated every three years and reviewed by the West Virginia Bureau for Public Health (WVBPH). For systems utilizing surface water or groundwater under the direct influence of surface water (GWUDI), SWPPs provide a detailed strategy for protecting intake areas and the surrounding Zone of Critical Concern.

Because these types of sources are open to the environment, they generally have a higher susceptibility to contamination. This susceptibility rating does not mean your water is contaminated; rather, it indicates that conditions exist which could impact the source water if a release occurred due to the sensitive nature of the intake area. A public version of our current Source Water Protection Plan (if applicable) or further information regarding our specific source susceptibility is available for review at our office during normal business hours or by contacting Bob Scott at 304-632-1933. A Source Water Assessment may previously have been completed to identify potential sources of contamination and the susceptibility of our water source. You can view these historical assessment reports online at the WVBPH website: <https://www.wvdhhr.org/oehs/eed/swap/search.cfm>.

For more information on source water protection and to learn how you can help protect drinking water sources, visit the EPA at <https://www.epa.gov/sourcewaterprotection/how-can-you-help-protect-source-water>.

Chlorine/Chloramines Maximum	MPA	MPA Units	RAA	RAA Units
------------------------------	-----	-----------	-----	-----------

Disinfection Level				
11/1/2025 - 11/30/2025	2.14000	MG/L	2.00000	MG/L

AVAILABILITY OF MONITORING DATA FOR UNREGULATED CONTAMINANTS

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that do not yet have a drinking water standard set by the US Environmental Protection Agency (EPA). The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard. As our customers, you have a right to know that this data is available.

If you are interested in examining the results, please contact: [Joseph Goodnite] at [304-632-1633].

Unresolved Deficiency Date Identified	Facility	Comments
11/9/2021	DISTRIBUTION SYSTEM	System does not have an adequate corrosion control program. (40CFR141.80-141.91)Please implement an adequate corrosion control program. On the day of the site visit it was noted that the PSD did not have a formal cross connection control plan.
11/9/2021	FALLS VIEW STORAGE	The storage tank has a leak. (64CSR77-9.1.i)Please ensure the storage tank leak is repaired. This water storage facility has a leak near the base and should be permanently and professionally repaired.
11/9/2021	FALLS VIEW STORAGE	The storage tank overflow is not properly screened. (64CSR77-9.1. f.2)Please ensure proper screening is in place for the storage tank overflow.
9/25/2024	BOOMER TANK	The storage tank is not adequately secured. (64CSR77-9.1.d) Please ensure the storage tank is adequately secured.
9/25/2024	CHARLTON HEIGHTS STORAGE	The storage tank is not adequately secured. (64CSR77-9.1.d) Access ladder gate is not secured. Please ensure the storage tank has a proper access ladder with secured access.
9/25/2024	CHARLTON HEIGHTS STORAGE	The storage tank site is not adequately fenced. (64CSR77-9.1.d) The fence is heavily damage and allows access to the interior of the facility. Please repair the fence immediately.
9/25/2024	DISTRIBUTION SYSTEM	System has a grossly unacceptable unaccounted water loss. (WVPSC Regulation 150CSR7-5.6. a) The reported unaccounted for water loss noted in the 2023 WVPSC Annual Report was ~67%. Please lower the system's excessive unaccounted for water loss with a ultimate goal of being less than 15%.
9/25/2024	FALLS VIEW STORAGE	The storage tank is not adequately secured. (64CSR77-9.1.d) There is no fence around this facility to prevent unwanted access. Please ensure the storage tank is adequately secured.
9/25/2024	FALLS VIEW STORAGE	The storage tank site is not fenced. (64CSR77-9.1.d) Please ensure the storage tank site is adequately fenced.
9/25/2024	FALLS VIEW TANK 2	The storage tank is not adequately secured. (64CSR77-9.1.d) There is no fence around this facility to prevent unwanted access. Please ensure the storage tank is adequately secured.
9/25/2024	FALLS VIEW TANK 2	The storage tank site is not fenced. (64CSR77-9.1.d) Please ensure the storage tank site is adequately fenced.
9/25/2024	GAULEY BRIDGE STORAGE (LOW)	The storage tank is not adequately secured. (64CSR77-9.1.d) Please ensure the storage tank is adequately secured.
9/25/2024	TREATMENT PLANT	The chlorine room does not have a properly functioning leak detector. (64CSR77-7.4.c)Please ensure the chlorine room has a properly functioning leak detector.
9/25/2024	TREATMENT PLANT	The system has treatment units that are not in good physical condition. The treatment units show signs of significant corrosion; the air scour device is not functioning; the flocculation paddles are not functioning; there is significant leakage around the bottom of the treatment unit. This is likely the source that is draining filter #1 when the system is not in operation. Please ensure that all of the deficiencies noted with the treatment units are repaired immediately.

Total Organic Carbon Lowest Month for Removal	Facility Name	Collection Date	Highest Value	Range	Unit	TT	Typical Source
CARBON, TOTAL	KANAWHA RIVER - INTAKE	11/24/2025	2	0.86 - 2	MG/L	0	Naturally present in the environment

Analyte	Facility Name	Highest Value	Unit of Measure	Month Occurred
Turbidity	TREATMENT PLANT	0.41	NTU	February

Turbidity

Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration.

Percentage of samples in compliance with Std	Months Occurred	Violation	Highest Single Measurement	Month Occurred	Sources	Level Indicator
92.00	12	NO	0.41	February	TREATMENT PLANT	NO

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.

TOC	Collection Date	Highest Value	Range	Unit	TT	Typical Source
CARBON, TOTAL	11/24/2025	2	0.86 - 2	MG/L	0	Naturally present in the environment

Secondary Contaminants-Non Health Based Contaminants-No Federal Maximum Contaminant Level (MCL) Established.	Collection Date	Highest Value	Range (low/high)	Unit	SMCL
SODIUM	11/13/2023	6.4	6.4	MG/L	20

During the 2025 calendar year, we had the below noted violation(s) of drinking water regulations.

Fed Rep ID	Compliance Period	Violation Type	Category	Rule	Explanation	Actions Taken by Water System
568992	1/1/2020 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	RADIUM-228	No monitoring samples were taken or reported	
568991	1/1/2020 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	GROSS ALPHA, EXCL. RADON & U	No monitoring samples were taken or reported	
568917	1/1/2023 - 12/31/2023	PUBLIC NOTICE RULE LINKED TO VIOLATION	PN	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state	
568918	1/1/2023 - 12/31/2023	PUBLIC	PN	PUBLIC	Failed to issue public notice	

		NOTICE RULE LINKED TO VIOLATION		NOTICE	or failed to provide a copy of the notice and certification to the state	
568957	1/1/2023 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	PICLORA M	No monitoring samples were taken or reported	
568958	1/1/2023 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	OXAMYL	No monitoring samples were taken or reported	
568923	1/1/2024 - 3/31/2024	PUBLIC NOTICE RULE LINKED TO VIOLATION	PN	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state	
568924	1/1/2024 - 3/31/2024	PUBLIC NOTICE RULE LINKED TO VIOLATION	PN	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state	
568925	1/1/2024 - 3/31/2024	PUBLIC NOTICE RULE LINKED TO VIOLATION	PN	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state	
568926	1/1/2024 - 12/31/2024	PUBLIC NOTICE RULE LINKED TO VIOLATION	PN	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state	
568927	3/1/2024 - 3/31/2024	PUBLIC NOTICE RULE LINKED TO VIOLATION	PN	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state	
568928	3/1/2024 - 3/31/2024	PUBLIC NOTICE RULE LINKED TO VIOLATION	PN	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state	
568944	4/1/2024 - 6/30/2024	PUBLIC NOTICE RULE LINKED TO VIOLATION	PN	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state	
568945	4/1/2024 - 6/30/2024	PUBLIC NOTICE RULE LINKED TO VIOLATION	PN	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state	
568961	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	XYLENES, TOTAL	No monitoring samples were taken or reported	
568965	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	VINYL CHLORID E	No monitoring samples were taken or reported	
568972	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	TRICHLO ROETHYL ENE	No monitoring samples were taken or reported	
568967	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	TRANS- 1,2- DICHLOR OETHYLE NE	No monitoring samples were taken or reported	
568977	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	TOLUENE	No monitoring samples were taken or reported	
568982	1/1/2025 - 12/31/2025	MONITORING,	MON	THALLIUM	No monitoring samples were	

		ROUTINE MAJOR		, TOTAL	taken or reported	
568974	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	TETRACH LOROETH YLENE	No monitoring samples were taken or reported	
568979	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	STYRENE	No monitoring samples were taken or reported	
568980	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	SODIUM	No monitoring samples were taken or reported	
568981	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	SELENIU M	No monitoring samples were taken or reported	
568964	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	P- DICHLO ROBENZEN E	No monitoring samples were taken or reported	
568963	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	O- DICHLO ROBENZEN E	No monitoring samples were taken or reported	
568985	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	NICKEL	No monitoring samples were taken or reported	
568986	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	MERCURY	No monitoring samples were taken or reported	
568978	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	ETHYLBE NZENE	No monitoring samples were taken or reported	
568962	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	DICHLO ROMETHAN E	No monitoring samples were taken or reported	
568987	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	CYANIDE	No monitoring samples were taken or reported	
568960	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	CIS-1,2- DICHLO ROETHYLE NE	No monitoring samples were taken or reported	
568988	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	CHROMIU M	No monitoring samples were taken or reported	
568975	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	CHLOROB ENZENE	No monitoring samples were taken or reported	
568922	1/1/2025 - 3/31/2025	MONITORING, ROUTINE (DBP), MAJOR	MON	CARBON, TOTAL	Failed to monitor/report as required for chlorine or disinfection by-products	
568970	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	CARBON TETRACH LORIDE	No monitoring samples were taken or reported	
568989	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	CADMIUM	No monitoring samples were taken or reported	
568983	1/1/2025 - 12/31/2025	MONITORING, ROUTINE	MON	BERYLLIU M. TOTAL	No monitoring samples were taken or reported	

		MAJOR				
568976	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	BENZENE	No monitoring samples were taken or reported	
568990	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	BARIUM	No monitoring samples were taken or reported	
568984	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	ANTIMONY, TOTAL	No monitoring samples were taken or reported	
568971	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	1,2-DICHLOROPROPANE	No monitoring samples were taken or reported	
568968	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	1,2-DICHLOROETHANE	No monitoring samples were taken or reported	
568959	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	1,2,4-TRICHLOROBENZENE	No monitoring samples were taken or reported	
568966	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	1,1-DICHLOROETHYLENE	No monitoring samples were taken or reported	
568973	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	1,1,2-TRICHLOROETHANE	No monitoring samples were taken or reported	
568969	1/1/2025 - 12/31/2025	MONITORING, ROUTINE MAJOR	MON	1,1,1-TRICHLOROETHANE	No monitoring samples were taken or reported	
568920	2/1/2025 - 2/28/2025	MONITORING, ROUTINE (IESWTR/LT1), MINOR	MON	TURBIDITY	Failed to collect and/or report all required turbidity samples or MCL	
568919	2/1/2025 - 2/28/2025	MONTHLY COMB FLTR EFFLUENT (IESWTR/LT1)	TT	TURBIDITY	Turbidity exceedance (monthly)	
568940	4/1/2025 - 6/30/2025	INADEQUATE DBP PRECURSOR REMOVAL	TT	CARBON, TOTAL	Inadequate disinfection by-product precursor removal	
568942	5/31/2025 - 9/10/2025	PUBLIC NOTICE RULE LINKED TO VIOLATION	PN	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state	
568943	5/31/2025 - 11/13/2025	PUBLIC NOTICE RULE LINKED TO VIOLATION	PN	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state	
568939	5/31/2025	FAILURE ADDRESS DEFICIENCY (EPA SURVEY)	TT	LT2ESWTR	Failed to address a deficiency	
568938	5/31/2025 - 11/13/2025	FAILURE ADDRESS	TT	LT2ESWTR	Failed to address a deficiency	

		DEFICIENCY (EPA SURVEY)				
568993	7/1/2025 - 12/31/2025	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	MON	LEAD & COPPER RULE	Failed to comply with follow-up or routine tap monitoring requirements related to lead and copper	
568941	7/1/2025 - 8/20/2025	CCR REPORT	RPT	CONSUMER CONFIDENCE RULE	Failed to deliver Consumer Confidence Report to the state or consumers on time	
568948	10/1/2025 - 10/31/2025	MONITORING, ROUTINE, MINOR (RTCR)	MON	E. COLI	Failed to collect all routine or replacement coliform samples	
568950	10/1/2025 - 10/31/2025	FAILURE TO COMPLETE OR SUBMIT MOR	MON	CHLORINE		
568955	10/1/2025 - 10/31/2025	MONITORING, ROUTINE (DBP), MAJOR	MON	CHLORINE	Failed to monitor/report as required for chlorine or disinfection by-products	
568949	10/1/2025 - 10/31/2025	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	MON	CHLORINE	Failed to collect and/or report required surface water treatment monitoring	
568951	11/1/2025 - 11/30/2025	FAILURE TO COMPLETE OR SUBMIT MOR	MON	CHLORINE		
568956	11/1/2025 - 11/30/2025	MONITORING, ROUTINE (DBP), MAJOR	MON	CHLORINE	Failed to monitor/report as required for chlorine or disinfection by-products	
568952	11/1/2025 - 11/30/2025	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	MON	CHLORINE	Failed to collect and/or report required surface water treatment monitoring	

AVAILABILITY OF MONITORING DATA FOR UNREGULATED CONTAMINANTS

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that do not yet have a drinking water standard set by the US Environmental Protection Agency (EPA). The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard. As our customers, you have a right to know that this data is available.

If you are interested in examining the results, please contact: (Contact Name) at (Phone Number)

Additional Required Health Effects Language:

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

Additional Required Health Effects Violation notices:

Total organic carbon (TOC) has no health effects. However, TOC provides a medium for the formation of disinfection byproducts (DBPs). These byproducts include Trihalomethanes (THMs) and Haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increase risk of getting cancer.

Testing Results for: Seller Name